

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			BPA NO.		1. CONTRACT ID CODE		PAGE 1		OF PAGES 3			
2. AMENDMENT/MODIFICATION NO. A00002			3. EFFECTIVE DATE 09-04-2014		4. REQUISITION/PURCHASE REQ. NO.			5. PROJECT NO.(If applicable) 442-14-79S				
6. ISSUED BY CODE 00259 Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246			7. ADMINISTERED BY (If other than Item 6) CODE 00259 Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246									
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders						(X)		9A. AMENDMENT OF SOLICITATION NO. VA259-14-Q-0675				
								9B. DATED (SEE ITEM 11) 09-04-2014				
						X		10A. MODIFICATION OF CONTRACT/ORDER NO.				
								10B. DATED (SEE ITEM 13)				
CODE			FACILITY CODE									
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS												
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.												
12. ACCOUNTING AND APPROPRIATION DATA (If required)												
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.												
(X) A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.												
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).												
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:												
D. OTHER (Specify type of modification and authority)												
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return ¹ _____ copies to the issuing office.												
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) a) A site visit was held on 8/26/2014 and the list of attendees is attached. b) Questions and answers received prior to the date required for submission are attached. c) The date set for the receipt of offers has been changed to 9/16/2014 at 3:00 pm (MST). d) The following attachments are included: Main Building drawing, and the Site drawing.												
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.												
15A. NAME AND TITLE OF SIGNER (Type or print)					16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Andrew Stigen Contracting Officer							
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)				15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)			16C. DATE SIGNED			
NSN 7540-01-152-8070 PREVIOUS EDITION NOT USABLE											STANDARD FORM 30 (REV. 10-83) Prescribed by GSA - FAR (48 CFR) 53.243	

PAMNS 8-26-2014

Michael S BELL VA 307 778 7350 x7294

michael.bell112@VA.GOV

SUSAN WEST

Premisys Support Group (PSG-)

THOMAS SALAZAR

PSG-

SWEST@TSSF.Into

Keith Mullings

SDVO-Techsico

TSS/C MINISTROWL.COM

Keith.mullings@techsico.com

Rob Billings

GCS LLC

rbillings@gcs-llc.net

Jim Martino

VA

james.martino@va.gov

302-778-7345

Roger Neupert

VA

Roger.Neupert@VA.GOV

302 778.7550 EX 7979

JIM WEBSTER

BEACON COMMUNICATIONS

jwebster@beaconcom.com

720-333-5550

Mark Toller

Beacon Communications

mtoller@beaconcom.com

720-363-6878

Questions/comments

1. The revised statement of work list the PoP as 270 days in Section 1.1-B and PoP as 160 days section 5.0-A. Please clarify.

Section 1.1-B states: "Work shall be complete, Occupational Safety and Health Administration (OSHA), National Recognized Testing Laboratory (NRTL – i.e. Underwriters Laboratory [UL]) Listed and Labeled; and VA Central Office (VACO), Telecommunications Voice Engineering (TVE 005OP3B) tested, certified and ready for operation within 270 days from Notice to Proceed."

Section 5.1-A states: "Construction shall be completed 160 calendar days from Notice to Proceed."

This means that the contractor has 160 days for construction and to install the system. The 270 days provides an additional 110 days to test, make changes and certify the system before the system needs to be operational.

2. A lot of the existing cables for the nurse call and public address systems are run "free air", can the new system be run "free air" or does it need to be run in conduits?

There is not a requirement for Low voltage wiring to be in conduit above the ceiling grid. There is a requirement that wiring cannot lay on the ceiling grid.

3. Does the old cabling need to be demoed and removed from the ceiling space?

Yes the old cabling will be removed.

4. One of the concerns with the PAMNS project was the number of zones needed.

There will need a minimum of 21 zones with an expansion capability.

5. Notes for the attached drawings:

- The red hatched areas are new construction.
- Building Names 1-A, 1-B, B-1, 1-C, 45, 1-CA and 1-CX are for reference only and should not be used. These are the old names for Arrowhead, Buffalo, Cowboy and Douglas Fir.
- Buildings 18, 19, 20, 23A, 25, 26, 31 and 42 are not to be considered for this project.